


Pebble Bed Reactor Project

MIT Nuclear Engineering Department




Economic Analysis of the Modular Pebble Bed Reactor

These slides present the conclusions of a preliminary study based on existing cost data found in “Evaluation of the Gas Turbine Helium Reactor” - DOE-HTGR-90380 - Dec. 1993 and compared against an NEI report issued in 1992 on the economics of alternative options. The purpose was to evaluate on a relative scale whether the pebble bed could be competitive. For the purposes of this study the gas price in 1992 was assumed constant and did not increase. This study will be revised as better data is developed.

June 1998

Ten-Unit MPBR Plant Layout (Top View)

(distances in meters)



Economic Analysis

- Group Goals
 - determine cost estimate for construction
 - compare cost estimate with that of existing technologies
 - examine financing options
 - examine economies of scale vs. productivity

MPBR Cost Estimate

- Capital cost
- O&M cost
- Fuel cost
- Decommissioning cost

Capital Cost

- Cost savings come from:
 - more factory fabrication, less site work
 - learning effect from 1st to 10th unit
 - natural safety features
 - shorter construction time
- Total capital cost for 1100 MWe plant
\$2,296 million


Plant Construction

- Construction Plan / Techniques
- Plant Physical layout
- Construction Model


Construction Plan / Techniques

- Factory Assembly
- Existing Technology
- Modular Construction Allows:
 - Parallel Construction
 - Ease of Shipment
 - Rapid Assembly
 - Streamlined Testing

Construction Flowpath for a Standard Unit




Graph for Unit 1




Unit 1 : Most Likely

Graph for Unit 6




Unit 6 : Most Likely

Graph for Unit 2




Unit 2 : Most Likely

Graph for Unit 7




Unit 7 : Most Likely

Graph for Unit 3




Unit 3 : Most Likely

Graph for Unit 8




Unit 8 : Most Likely

Graph for Unit 4




Unit 4 : Most Likely

Graph for Unit 9




Unit 9 : Most Likely

Graph for Unit 5




Unit 5 : Most Likely

Graph for Unit 10





Unit 10 : Most Likely

Unit Construction Flowpath




Graph for Instantaneous Work in Progress




Instantaneous Work in Progress : Most Likely  Week

Graph for Indirect Construction Expenses





Indirect Construction Expenses : Most Likely — Dollars/Week

Graph for hardware cost




hardware cost : Most Likely —

Graph for Income During Construction



Graph for Net Construction Expense




Net Construction Expense : Most Likely —

Construction Model


- Can it be done?
- Influence of external factors?
- What are vulnerabilities / areas for time and cost savings?
- What is the relationship between construction time and cash flow?
- Sensitivity analysis

Graph for Instantaneous Work in Progress



Instantaneous Work in Progress : Most Likely — Week
 Instantaneous Work in Progress : Unit-4 Hits Water — Week
 Instantaneous Work in Progress : Intervenors — Week
 Instantaneous Work in Progress : Module Delay — Week

Graph for Net Construction Expense



Net Construction Expense : Most Likely — Week
 Net Construction Expense : Unit-4 Hits Water — Week
 Net Construction Expense : Intervenors — Week
 Net Construction Expense : Module Delay — Week

MPBR PLANT CAPITAL COST ESTIMATE
(MILLIONS OF JAN. 1992 DOLLAR WITHOUT CONTINGENCY)

Account No.	Account Description	Cost Estimate
20	LAND & LAND RIGHTS	2.5
21	STRUCTURES & IMPROVEMENTS	192
22	REACTOR PLANT EQUIPMENT	628
23	TURBINE PLANT EQUIPMENT	316
24	ELECTRIC PLANT EQUIPMENT	64
25	MISCELLANEOUS PLANT EQUIPMENT	48
26	HEAT REJECT. SYSTEM	25
	TOTAL DIRECT COSTS	1,275
91	CONSTRUCTION SERVICE	111
92	HOME OFFICE ENGR. & SERVICE	63
93	FIELD OFFICE SUPV. & SERVICE	54
94	OWNER'S COST	147
	TOTAL INDIRECT COST	375
	TOTAL BASE CONSTRUCTION COST	1,650
	CONTINGENCY (M\$)	396
	TOTAL OVERNIGHT COST	2,046
	UNIT CAPITAL COST (\$/KWe)	1,860
	AFUDC (M\$)	250
	TOTAL CAPITAL COST	2296

O&M Cost

- Simpler design and more compact
- Least number of systems and components
- Small staff size: 150 personnel
- \$31.5 million per year

Fuel Cost

- Assumptions:
 - One fuel pebble will cost \$20.00 ('92\$)
 - One third of the fuel pebble bed is replaced annually (120,000 per unit per year)
 - 1.0 mill/kWh for spent fuel disposal and radioactive waste management
- Cost: \$32.7 million / year

Decommissioning Cost

- \$211 million
- Remove all radioactive wastes from site and all construction material to a level of 3ft below grade.
- Less than 1 mill/kWh levelized busbar cost

MPBR Busbar Generation Costs ('92\$)

Reactor Thermal Power (MWt)	10 x 250
Net Efficiency (%)	45.3%
Net Electrical Rating (Mwe)	1100
Capacity Factor (%)	90
Total Overnight Cost (M\$)	2,046
Levelized Capital Cost (\$/kWe)	1,860
Total Capital Cost (M\$)	2,296
Fixed Charge Rate (%)	9.47
30 Year Level Cost (M\$/yr):	
Levelized Capital Cost	217
Annual O&M Cost	31.5
Level Fuel Cycle Cost	32.7
Level Decommissioning Cost	<u>5.4</u>
Revenue Requirement	286.6
Busbar Cost (mill/kWhr):	
Capital	25.0
O&M	3.6
Fuel	3.8
Decommissioning	<u>0.6</u>
Total	33.0

Financing Construction

- Cost of capital
 - debt-to-equity ratio
 - distribution of risk
- Consortium approach
 - share risk
 - lower return on investment

Amortization of debt

- Determine annual revenue requirements
 - debt-to-equity ratio
 - return on preferred equity
 - return on common equity
 - income taxes

Debt Service Coverage

- Ratio of total revenue generated to annual revenue required
 - depends on amortization length
 - distribution of risk
- Consortium approach best

Competitive With Gas ?

- Natural Gas 3.4 Cents/kwhr
- AP 600 3.62 Cents/kwhr
- ALWR 3.8 Cents/kwhr
- MPBR 3.3 Cents/kwhr

Levelized Costs (1992 \$ Based on NEI Study)

Group Findings

- Low levelized cost
 - low fuel cost
 - low O&M cost
- High unit capital cost
 - low capacity design
 - high contingency factor (24%)

Future Work

- Determine optimal capital structure
- Adjust cost estimate to design changes
- Create detailed cash flow statement

Major MPBR Conclusions

- Naturally Safe (Regulatory / Safety Implications)
 - Constrained by Fuel Particle failure above 1600°C
 - Core power density chosen as 3.54 MW/m³
 - Fuel pebble manufacturing defects are the most significant source of fission product release
- Economically Competitive
 - 3.3 cents/kWhr (natural gas = 3.4 cents/kWhr)
 - Producing revenue within 3 years (rapid construction)
 - Low staffing and O&M costs
 - Factory Assembly
- Societal Acceptance
 - Proliferation Resistance -- promising, but future work needed
 - Waste Disposal -- promising, but future work needed